NEBRASKA ADMINISTRATIVE CODE

TITLE 229 - DEPARTMENT OF LABOR

CHAPTER 14 - CONDEMNED BOILERS OR PRESSURE VESSELS

001. This chapter is adopted pursuant to *Neb. Rev. Stat.* §48-727.

002. Any boiler or pressure vessel that has been recommended for condemnation shall be immediately discontinued from service.

003. The Department shall be promptly notified of such action and the Chief Boiler Inspector or a Deputy Inspector shall inspect the boiler or pressure vessel for final action.

004. Boilers and pressure vessels that are condemned by the Chief Boiler Inspector or a Deputy Inspector shall have, distinctly stamped over the State of Nebraska serial number, the following symbol: "XXX". In addition to stamping the metal tag the inspector shall affix a label to the unit showing that the unit has been condemned. If the metal tag is not on the unit, a label showing the serial number shall be attached to the unit. In the case of boilers that have numbers that are not physically stamped but are identified by an alternative labeling, the Chief Boiler Inspector or Deputy Inspector shall remove or destroy the alternative labeling device and then write "Condemned" in a conspicuous place on the unit.

005. Any person, firm, partnership or corporation using or offering for sale a condemned boiler or pressure vessel for operation within this jurisdiction shall be subject to the penalties provided for in the Act.

006. Any unit that has been condemned, and then repaired, shall be inspected by the Chief Boiler Inspector or a Deputy Inspector prior to any operation of the unit. A copy of all of the repair forms shall be presented to the inspector prior to the inspection.

APPROVED

AUG 02 2016

PETE RICKETTS
GOVERNOR

FILED

AUG - 2 2016

IN THE OFFICE OF SECRETARY OF STATE

APPROVED
DOUGLAS J. PETERSON
ATTORNEY GENERAL

JUL 11 2016

BY
ASSISTANT ATTORNEY GENERAL