

TITLE 228 - DEPARTMENT OF LABOR

CHAPTER 42 - INTERNAL COMBUSTION POWER SOURCES

001. This chapter is adopted pursuant to Neb. Rev. Stat. §48-1803.
002. Fuel tanks for internal combustion power sources should be of adequate capacity to permit uninterrupted operation during normal operating hours.
003. Where it is impossible to provide tanks of proper capacity for a complete day, the ride or device shall be shut down and unloaded or evacuated during the refueling procedure. The fuel supply shall not be replenished while the engines are running.
004. An enclosed area in which an internal combustion engine is operated shall be ventilated. Exhaust fumes from the engine shall be discharged outside the area. Internal combustion power sources shall be located in a manner and shall be protected either by guards, fencing, or enclosure to prevent public exposure to hazard and to secure the equipment from the public.